



## Legislation Details

---

**File #:** 21-0897      **Version:** 1      **Name:**  
**Type:** Report Action Item      **Status:** Action Item  
**File created:** 6/16/2021      **In control:** Board of Building Inspection  
**On agenda:** 6/21/2021      **Final action:** 6/21/2021  
**Title:** 700 S. Weimar St. (31-4-1709-00) The existing headroom on the stair is 5' 8", Section 321.04(2)(d) of the UDC requires the headroom to be 6'4".

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 700 S. Weimar St.pdf

Date	Ver.	Action By	Action	Result
6/21/2021	1	Board of Building Inspection	approved	Pass