



Legislation Details

File #: 22-0821 **Version:** 2 **Name:**

Type: Report Action Item **Status:** Action Item

File created: 6/24/2022 **In control:** Board of Building Inspection

On agenda: 6/30/2022 **Final action:** 6/30/2022

Title: 35 Bellaire Ct (31-1-1264-00) Request to continue to use an existing stair that is less than three (3) feet wide, with a doorway that has no landing. Section 321-04(2)(a) of the Uniform Dwelling Code as adopted by Section 4-136 of the Municipal Code, requires stairs to be three (3) feet in width and have a three (3) foot landing.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 35 BellaireCt.pdf

Date	Ver.	Action By	Action	Result
6/30/2022	2	Board of Building Inspection	approved	Pass