



## Legislation Details

---

**File #:** 15-1109      **Version:** 1      **Name:**

**Type:** Report Action Item      **Status:** Action Item

**File created:** 6/29/2015      **In control:** Board of Building Inspection

**On agenda:** 7/7/2015      **Final action:** 7/7/2015

**Title:** 625 W. Prospect Ave. (31-3-0332-00) The porch on this property is being renovated due to structural deterioration. In order to maintain the historic character of the home, the applicant is proposing a handrail height of 25 1/2" and guardrail height of 25 1/2". Section 321.04(3)(c)(2) Uniform Dwelling Code requires a minimum 36" guardrail height and Section 321.04(3)(b) requires 30-38" handrail height.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 625 W. Prospect Ave.pdf

Date	Ver.	Action By	Action	Result
7/7/2015	1	Board of Building Inspection	approved	Pass