



Legislation Details

File #: 17-116 **Version:** 1 **Name:**

Type: Report Action Item **Status:** Action Item

File created: 1/26/2017 **In control:** Board of Building Inspection

On agenda: 1/31/2017 **Final action:** 1/31/2017

Title: 702 E. North St. (31-1-0267-00). The applicant proposed construction of a guardrail that is twenty-seven (27) inches tall. Section 321-04(3)(c) of the Uniform Dwelling Code requires that guardrails are thirty-six(36) inches tall.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 702 E. North St Application and pictures.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|------------------------------|----------|--------|
| 1/31/2017 | 1 | Board of Building Inspection | approved | Pass |