



Legislation Details (With Text)

File #: 17-802 **Version:** 1 **Name:**

Type: Report Action Item **Status:** Action Item

File created: 5/25/2017 **In control:** Board of Building Inspection

On agenda: 5/31/2017 **Final action:** 5/31/2017

Title: 1718 E Wisconsin Ave (31-1-3987-25). The applicant proposes to build a fire wall that is not continuous from the ground to the roof. Section 706.6 of the International Building Code requires fire walls to be continuous.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 1718 E. Wisconsin Ave(map).pdf, 2. 1718 E. Wisconsin Ave.pdf

Date	Ver.	Action By	Action	Result
5/31/2017	1	Board of Building Inspection	approved	Pass

1718 E Wisconsin Ave (31-1-3987-25). The applicant proposes to build a fire wall that is not continuous from the ground to the roof. Section 706.6 of the International Building Code requires fire walls to be continuous.