



Legislation Details (With Text)

File #: 21-1313 **Version:** 1 **Name:**

Type: Report Action Item **Status:** Action Item

File created: 9/14/2021 **In control:** Board of Building Inspection

On agenda: 9/15/2021 **Final action:** 9/15/2021

Title: 5300 N. Meade St. (31-1-8500-00) The Applicant is proposing to construct an athletic storage building with the stair riser height to be 8" and the tread depth to be 9". Section 4-136 of the Municipal Code (IBC 1011.5.2 of the Commercial Code) requires riser height to be a maximum of 7" and tread depth to be a minimum of 11".

Sponsors:

Indexes:

Code sections:

Attachments: 1. 5300 N. Meade St.pdf

Date	Ver.	Action By	Action	Result
9/15/2021	1	Board of Building Inspection	approved	Pass

5300 N. Meade St. (31-1-8500-00) The Applicant is proposing to construct an athletic storage building with the stair riser height to be 8" and the tread depth to be 9". Section 4-136 of the Municipal Code (IBC 1011.5.2 of the Commercial Code) requires riser height to be a maximum of 7" and tread depth to be a minimum of 11".