



## Legislation Details

---

**File #:** 21-1313      **Version:** 1      **Name:**

**Type:** Report Action Item      **Status:** Action Item

**File created:** 9/14/2021      **In control:** Board of Building Inspection

**On agenda:** 9/15/2021      **Final action:** 9/15/2021

**Title:** 5300 N. Meade St. (31-1-8500-00) The Applicant is proposing to construct an athletic storage building with the stair riser height to be 8" and the tread depth to be 9". Section 4-136 of the Municipal Code (IBC 1011.5.2 of the Commercial Code) requires riser height to be a maximum of 7" and tread depth to be a minimum of 11".

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 5300 N. Meade St.pdf

| Date      | Ver. | Action By                    | Action   | Result |
|-----------|------|------------------------------|----------|--------|
| 9/15/2021 | 1    | Board of Building Inspection | approved | Pass   |