



## Legislation Details (With Text)

---

**File #:** 21-1739      **Version:** 1      **Name:**  
**Type:** Report Action Item      **Status:** Reported from Committee  
**File created:** 12/28/2021      **In control:** Board of Building Inspection  
**On agenda:** 1/6/2022      **Final action:**  
**Title:** 101 W. Edison Ave (31-4-0257-00) The applicant is requesting a variance be granted to not install automatic sprinklers as required in the SPS 362.0903(2) (as adopted by Section 4-136 of the Municipal Code) for a space that will be used as an A-2 use group, where alcohol will be consumed and the occupant load is limited to 200 persons.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 101 W. Edison Ave.pdf

Date	Ver.	Action By	Action	Result
1/6/2022	1	Board of Building Inspection	recommended for denial	Pass

**101 W. Edison Ave (31-4-0257-00)** The applicant is requesting a variance be granted to not install automatic sprinklers as required in the SPS 362.0903(2) (as adopted by Section 4-136 of the Municipal Code) for a space that will be used as an A-2 use group, where alcohol will be consumed and the occupant load is limited to 200 persons.