



City of Appleton

100 North Appleton Street
Appleton, WI 54911-4799
www.appleton.org

Legislation Text

File #: 17-116, **Version:** 1

702 E. North St. (31-1-0267-00). The applicant proposed construction of a guardrail that is twenty-seven (27) inches tall. Section 321-04(3)(c) of the Uniform Dwelling Code requires that guardrails are thirty-six(36) inches tall.