



City of Appleton

100 North Appleton Street
Appleton, WI 54911-4799
www.appleton.org

Legislation Text

File #: 17-802, **Version:** 1

1718 E Wisconsin Ave (31-1-3987-25). The applicant proposes to build a fire wall that is not continuous from the ground to the roof. Section 706.6 of the International Building Code requires fire walls to be continuous.