

City of Appleton

100 North Appleton Street Appleton, WI 54911-4799 www.appleton.org

Legislation Text

File #: 21-1313, Version: 1

5300 N. Meade St. (31-1-8500-00) The Applicant is proposing to construct an athletic storage building with the stair riser height to be 8" and the tread depth to be 9". Section 4-136 of the Municipal Code (IBC 1011.5.2 of the Commercial Code) requires riser height to be a maximum of 7" and tread depth to be a minimum of 11".